

C. A. CROWLEY ENGINEERING, INC.  
645 County Street  
Taunton, MA 02780

**TO ALL BIDDERS:**

DATE: February 26, 2024

PROJECT NAME: Lowell Housing Authority  
North Common Village  
Boiler Replacement  
LHA IFB #2024-2

---

**Addendum No. 2**

This addendum shall become a part of the Contract Documents and as such all bidders should acknowledge it on the Form for General Bid. Failure to do so may result in the rejection of your bid.

**RESPONSES TO BIDDER RFIs**

- Q1. Alternate #1 indicates a circulating pump at the new water heater. Please provide a schedule and specification for this pump.
- A1. Pump is supplied with the water heater. According to the installation manual the standard pump is rated at 270gpm, 24' head.

**END of Addendum No. 2**